



- **News**
- **Evaluating Different Financing Packages for Mobile Home HVAC**
Evaluating Different Financing Packages for Mobile Home HVAC **Budgeting Monthly Payments for Mobile Home Heating Projects** **Reviewing Interest Options for Mobile Home AC Installations** **Setting Up Installment Plans for Mobile Home Furnace Upgrades** **Comparing Credit Requirements for Mobile Home HVAC Financing** **Investigating No Payment Period Deals for Mobile Home Cooling** **Combining Rebates with Financing for Mobile Home AC Purchases** **Checking Eligibility for Income Based Mobile Home HVAC Loans** **Aligning Payment Strategies with Seasonal Needs in Mobile Home Heating** **Exploring Collaboration with Utility Incentive Programs for Mobile Homes** **Scheduling Payments for Large Scale Mobile Home HVAC Replacements** **Simplifying Approval Steps for Mobile Home HVAC Financing**
- **Exploring Major Brands for Mobile Home Furnace Installations**
Exploring Major Brands for Mobile Home Furnace Installations **Aligning System Specifications with Mobile Home AC Requirements** **Evaluating Carrier Options for Mobile Home Air Conditioning** **Navigating Trane Models for Mobile Home Heating** **Selecting Goodman Units for Reliable Mobile Home Climate Control** **Verifying Rheem Specifications in Mobile Home HVAC Retrofits** **Identifying Compatible Parts Across Multiple Mobile Home Brands** **Adapting Different Brand Coils and Compressors for Mobile Home Use** **Maintaining Uniform Performance with Mixed Brand Components** **Comparing Equipment Sizes to Mobile Home Square Footage** **Assessing Future Upgrade Paths for Mobile Home AC Brand Choices** **Checking Warranties Offered by Various Mobile Home HVAC Brands**
- **About Us**



Navigating Trane Models for Mobile Home Heating

Overview of HVAC needs specific to mobile homes

Choosing the right heating system for a mobile home is not merely a matter of comfort; it's an essential decision that impacts energy efficiency, safety, and cost-effectiveness. Mobile homes, unlike traditional houses, have unique structural and insulation characteristics that require specific heating solutions. When navigating through Trane models for mobile home heating, understanding these nuances becomes crucial in making an informed choice.

Firstly, one must consider the size and layout of the mobile home. Mobile homes often have limited space and different ventilation needs compared to conventional homes. A heating system that is too large can lead to inefficiencies and unnecessary energy consumption, while one that is too small may struggle to maintain a comfortable temperature during colder months. Trane offers a range of models designed with varying capacities to suit different home sizes, ensuring optimal performance and energy use.

Professional inspection is necessary before installing a new HVAC unit **replacing hvac system in mobile home** condenser.

Energy efficiency is another critical factor when selecting a heating system for your mobile home. Given the rising costs of energy and growing environmental concerns, opting for a system with high-efficiency ratings can lead to significant savings on utility bills over time. Trane's lineup includes Energy Star-rated systems known for their reliability and efficiency. These models not only help reduce carbon footprints but also translate into lower operating costs—a compelling advantage for budget-conscious homeowners.

Safety cannot be overlooked either when considering heating options for mobile homes. The materials used in constructing these homes are sometimes more susceptible to fire hazards than those in traditional housing structures. Therefore, choosing a reliable brand like Trane, which has built its reputation on safety standards and rigorous testing procedures, provides peace of mind.

Moreover, ease of installation and maintenance should factor into your decision-making process. Mobile homes frequently have distinct installation requirements due to their size constraints and construction methods. Trane offers comprehensive support services with their products, ensuring that homeowners can access professional installation advice or service technicians if needed.

Finally, personal comfort preferences play an integral role in selecting the right model from Trane's offerings. Whether it's desiring precise temperature control or minimal noise disruption during operation, Trane's diverse range allows homeowners to prioritize features most important to them without compromising on quality or durability.

In conclusion, selecting the right heating system for a mobile home involves balancing multiple factors-size compatibility, energy efficiency, safety considerations, ease of maintenance-and personal comfort needs. By carefully navigating through available Trane models tailored specifically for mobile homes' unique demands, homeowners can enjoy year-round warmth while maximizing efficiency and minimizing costs. Making an informed decision in this regard not only enhances living conditions but also contributes positively towards long-term economic savings and environmental sustainability.

Importance of efficient heating and cooling solutions —

- **Overview of HVAC needs specific to mobile homes**
- **Importance of efficient heating and cooling solutions**
- **Understanding Financing Options for Mobile Home HVAC**
- **Explanation of common financing packages available**
- **Key factors to consider when choosing a financing option**
- **Personal Loans for HVAC Systems**
- **Pros and cons of using personal loans for HVAC installation**

Trane is a well-established name in the HVAC (heating, ventilation, and air conditioning) industry, renowned for its commitment to quality, reliability, and innovation. As a leading brand in this space, Trane has built a reputation over the decades for producing robust and efficient heating and cooling systems that cater to various needs, including those of mobile home owners. Navigating Trane models specifically designed for mobile home heating can be an

enlightening journey into high-performance solutions tailored to meet unique spatial and environmental requirements.

Trane's dedication to excellence begins with their rigorous testing processes. Each unit undergoes extensive trials to ensure it can withstand extreme conditions while maintaining peak efficiency. This attention to detail sets Trane apart as a brand that mobile homeowners can trust. The company's diverse range of heating solutions means there is likely a model suited perfectly for any mobile home scenario.

Mobile homes present unique challenges when it comes to heating due to their size constraints and often less-than-optimal insulation compared to traditional houses. Recognizing these challenges, Trane offers models that are compact yet powerful enough to deliver consistent warmth throughout the living space. Their heat pumps and furnaces come equipped with advanced technologies designed not only for efficiency but also for ease of installation—a crucial feature in the often-tighter confines of mobile homes.

Among Trane's offerings are energy-efficient heat pumps that serve dual purposes: providing warmth during colder months and cooling during warmer ones. This dual functionality is particularly beneficial in regions where temperature fluctuations are common throughout the year. By opting for such versatile systems, mobile homeowners can achieve comfort all year round without the need for multiple appliances.

Furthermore, Trane emphasizes sustainability through its products by adhering to strict energy efficiency standards. Many of their models boast high SEER (Seasonal Energy Efficiency Ratio) ratings which translate into lower utility bills—a significant consideration given the rising energy costs today. For environmentally conscious consumers or those simply looking to reduce overhead costs, this focus on eco-efficiency is highly appealing.

Navigating through Trane's array of models requires considering specific needs such as climate zone suitability, budget constraints, and personal preferences regarding features like programmable thermostats or smart home compatibility. Fortunately, Trane offers resources and expert consultations that guide customers toward making informed decisions tailored specifically for their circumstances.

In conclusion, as a leader in HVAC solutions, Trane provides reliable options designed with both performance and practicality in mind—qualities especially vital when addressing the distinct demands of mobile home environments. Through continued innovation and

unwavering dedication to customer satisfaction, Trane remains a top choice among homeowners seeking dependable heating solutions adaptable across various contexts-proving once again why it's considered one of the best in the industry. Whether you're new to navigating HVAC options or looking to upgrade an existing system within your mobile home, turning towards Trane could very well be your first step towards enhanced comfort and peace of mind year-round.


Affordable Payment Plans for Upgrading Mobile Home AC Systems



Choosing the right payment plan for upgrading your mobile home AC system is a crucial decision that can significantly impact your financial stability and comfort at home.. With numerous options available, it's essential to consider several factors to ensure you select a plan that aligns with your needs and budget. Firstly, assess your financial situation.

Posted by on 2024-12-30

Aligning Equipment Compatibility with Financing Options in Mobile Homes



In the dynamic world of mobile homes, aligning equipment compatibility with financing options is a crucial element that can significantly impact the success of any project.. The process involves

ensuring that the equipment used in mobile home construction or renovation is not only technically suitable but also financially feasible.

Posted by on 2024-12-30

Understanding Financing Options for Mobile Home HVAC

When it comes to heating mobile homes, choosing the right system is crucial for ensuring comfort and energy efficiency. Among the various options available, Trane models stand out as a reliable choice. Renowned for their durability and advanced technology, these models offer several key features and benefits tailored specifically for mobile home environments.

One of the primary features of Trane heating systems is their robust design, engineered to withstand various environmental challenges that mobile homes might face. Unlike traditional homes, mobile homes often experience more significant temperature fluctuations due to their construction materials and mobility. Trane models are designed with this in mind, providing consistent performance even in extreme weather conditions. This reliability ensures that homeowners can enjoy a warm and comfortable living space regardless of external temperatures.


Energy efficiency is another hallmark of Trane heating systems. With rising energy costs, it's important for homeowners to consider systems that not only perform well but also help reduce utility bills. Trane models often come equipped with high-efficiency ratings, meaning they convert more fuel into heat compared to less efficient systems. This translates to lower energy consumption and reduced greenhouse gas emissions—a win-win for both your wallet and the environment.

Moreover, many Trane models feature state-of-the-art technology that enhances user convenience and control. For instance, some units are compatible with smart thermostats, allowing users to adjust settings remotely via smartphones or other devices. This technological integration offers greater flexibility in managing home temperatures according to personal schedules and preferences while optimizing energy use.

Trane's commitment to quality extends beyond just product performance; it also includes a focus on customer satisfaction through comprehensive warranties and support services. These warranties provide peace of mind by covering potential repairs or replacements over an extended period, ensuring that your investment remains protected.

Furthermore, installation ease is another benefit worth mentioning when considering Trane models for mobile homes. Designed with streamlined setups in mind, these systems can be installed efficiently by professionals without extensive modifications or disruptions to the existing structure of the home.

In summary, navigating through Trane's range of heating solutions reveals an array of features specifically beneficial for mobile home owners—from robust designs capable of enduring diverse climates to advanced technologies promoting energy efficiency and convenience. Choosing a Trane model means investing in long-term comfort backed by reliable performance and exceptional customer support—all vital components when searching for the ideal heating solution tailored to meet the unique demands of a mobile home environment.



Explanation of common financing packages available

When it comes to heating your mobile home, choosing the right Trane model can make a significant difference in comfort, efficiency, and cost-effectiveness. Navigating the array of Trane models available requires careful consideration of several key factors to ensure that you select the best fit for your specific needs.

First and foremost, consider the size and layout of your mobile home. Mobile homes vary greatly in size, from compact single-wides to more spacious double-wides. The square footage will directly influence the capacity required from your heating system. An undersized unit will struggle to maintain heat during colder months, leading to increased energy consumption and higher utility bills as it works overtime. Conversely, an oversized unit may cycle on and off too frequently, causing unnecessary wear and tear. Thus, conducting a proper load calculation or consulting a heating professional is crucial for determining the appropriate BTU (British Thermal Unit) rating needed for efficient operation.

Energy efficiency is another critical factor when selecting a Trane model. Modern advancements in HVAC technology have led to systems that are far more energy-efficient than their predecessors. Look for units with high Seasonal Energy Efficiency Ratio (SEER) ratings or Annual Fuel Utilization Efficiency (AFUE) ratings if you're considering a furnace. Higher ratings indicate better performance relative to energy consumption. Investing in an energy-efficient model might have higher upfront costs but will pay dividends through reduced energy bills over time.

Climate considerations also play a pivotal role in choosing the right heating solution for your mobile home. If you reside in an area with mild winters, a heat pump could be an excellent choice due to its dual capability of providing both heating and cooling efficiently. However, if you face harsh winter conditions regularly, opting for a furnace might offer better reliability and warmth throughout the season.

Another aspect worth examining is the compatibility with existing infrastructure within your mobile home. Some models might require additional ductwork or modifications which could increase installation costs significantly. Therefore, assessing whether your chosen system aligns with current setups can prevent unexpected expenses down the line.

Moreover, it's essential not only to focus on technical specifications but also customer support services provided by Trane dealers near you-ensuring availability of maintenance services post-installation ensures longevity of equipment life span along seamless functioning throughout its use phase.

Finally yet importantly is budgetary constraints; while premium models boast myriad features promising unparalleled comfort levels unfortunately they come at steep prices hence identifying balance between affordability without compromising quality remains paramount task potential buyers must undertake diligently before finalizing purchase decision

In conclusion: thoughtful deliberation over various facets including size requirements efficiency ratings climate adaptability infrastructural compatibility plus accessible service options culminates into informed selection process ultimately enhancing living experience within confines cozy confines beloved abode known fondly as 'mobile home'.

Key factors to consider when choosing a financing option

Navigating the world of Trane HVAC systems for mobile homes can seem daunting at first, but with a bit of guidance, you can ensure a comfortable and efficient climate control solution for your living space. Mobile homes present unique challenges due to their size and construction, making it crucial to select an HVAC system that is both effective and energy-efficient. Trane, a reputable name in the HVAC industry, offers a range of models designed to meet these specific needs.

When choosing a Trane model for your mobile home, it's essential to consider the size and layout of your home. Mobile homes typically require compact systems that maximize efficiency without overwhelming the space. Trane offers several options that are suitable for smaller living areas while still providing robust heating capabilities. For instance, their packaged systems are particularly well-suited for mobile homes as they combine heating and cooling functions into one unit, saving space and simplifying installation.

One of the key maintenance tips for ensuring longevity and optimal performance from your Trane HVAC system is regular filter replacement. In mobile homes, where air circulation might be more limited compared to traditional houses, filters can accumulate dust and debris quickly. Regularly checking and replacing these filters will not only improve air quality but also enhance the system's efficiency.

Another crucial aspect of maintaining your Trane system is scheduling periodic professional inspections. A certified technician can perform detailed checks on components such as the heat exchanger and thermostat calibration, ensuring everything operates smoothly. This


preventive measure helps identify potential issues before they escalate into costly repairs or replacements.

Additionally, it's advisable to keep an eye on the outdoor unit if you have a split system installed. Clear any debris like leaves or grass clippings that might obstruct airflow around the unit. Ensuring adequate airflow prevents overheating and reduces strain on the system.

Understanding how to operate your thermostat efficiently is another vital element in using your Trane HVAC system effectively in a mobile home setting. Programmable thermostats allow you to set temperatures according to your daily routine, potentially reducing energy consumption when heating isn't needed.

Finally, insulation plays a significant role in maintaining an evenly heated environment within mobile homes. Insufficient insulation can lead to heat loss during colder months, causing your HVAC system to work harder than necessary. Upgrading insulation or sealing gaps around windows and doors can complement your heating system's efforts by minimizing energy waste.

In conclusion, selecting the right Trane model tailored for mobile home use involves understanding both spatial constraints and specific heating needs. With diligent maintenance practices-such as regular filter changes, professional check-ups, outdoor unit care, efficient thermostat use-and proper insulation measures in place-you can navigate through various Trane models successfully while enjoying consistent warmth throughout colder seasons.





Personal Loans for HVAC Systems

Navigating Trane Models for Mobile Home Heating: Energy Efficiency and Cost-Effectiveness

When it comes to heating mobile homes, the importance of energy efficiency and cost-effectiveness cannot be overstated. With limited space and often higher exposure to the elements, mobile homes require heating solutions that are both powerful and economical. Among the myriad options available, Trane models stand out for their innovative approach in balancing these two crucial factors.

Trane has long been a leader in HVAC technology, renowned for their commitment to quality and performance. The brand's focus on energy efficiency is evident across its range of models designed specifically for mobile home heating. These systems incorporate advanced features such as variable speed technology and smart thermostats that optimize energy consumption by adjusting output based on real-time needs. This not only enhances comfort but significantly reduces unnecessary energy use, translating into lower utility bills.

One of the key aspects of Trane models' cost-effectiveness is their durability. Built with high-quality materials and robust engineering, these units are designed to withstand the rigors of continuous operation over many years. While the initial investment might be slightly higher compared to some other brands, Trane's longevity ensures that homeowners save money in the long run by avoiding frequent repair or replacement costs.

Moreover, Trane offers a variety of models tailored to different-sized mobile homes, ensuring that each unit delivers optimal performance without overexertion or waste. Whether it's a compact single-section home or a larger double-wide model, there's a suitable Trane system that maximizes efficiency while keeping operational costs in check.


Additionally, many Trane systems are eligible for energy rebates and tax incentives due to their high efficiency ratings. By choosing an Energy Star-certified model, homeowners can further offset initial costs while contributing positively to environmental conservation efforts.

In summary, navigating through Trane models for mobile home heating reveals a spectrum of choices that prioritize both energy efficiency and cost-effectiveness. These systems not only provide reliable warmth during colder months but also promote sustainable living through reduced energy consumption and long-term savings. For those seeking an ideal blend of performance and economy in their mobile home heating solutions, Trane remains an exemplary choice.

About Refrigerant



This article's lead section may be too short to adequately summarize the key points. Please consider expanding the lead to provide an accessible overview of all important aspects of the article. (March 2021)



A DuPont R-134a refrigerant

A **refrigerant** is a working fluid used in cooling, heating or reverse cooling and heating of air conditioning systems and heat pumps where they undergo a repeated phase transition from a liquid to a gas and back again. Refrigerants are heavily regulated because of their toxicity and flammability^[1] and the contribution of CFC and HCFC refrigerants to ozone depletion^[2] and that of HFC refrigerants to climate change.^[3]

Refrigerants are used in a direct expansion (DX- Direct Expansion) system (circulating system) to transfer energy from one environment to another, typically from inside a building to outside (or vice versa) commonly known as an air conditioner cooling only or cooling & heating reverse DX system or heat pump a heating only DX cycle. Refrigerants can carry 10 times more energy per kg than water, and 50 times more than air.


Refrigerants are controlled substances and classified by International safety regulations ISO 817/5149, AHRAE 34/15 & BS EN 378 due to high pressures (700–1,000 kPa (100–150 psi)), extreme temperatures (?50 °C [?58 °F] to over 100 °C [212 °F]), flammability (A1 class non-flammable, A2/A2L class flammable and A3 class extremely flammable/explosive) and toxicity (B1-low, B2-medium & B3-high). The regulations relate to situations when these refrigerants are released into the atmosphere in the event of an accidental leak not while circulated.

Refrigerants (controlled substances) must only be handled by qualified/certified engineers for the relevant classes (in the UK, C&G 2079 for A1-class and C&G 6187-2 for A2/A2L & A3-class refrigerants).

Refrigerants (A1 class only) Due to their non-flammability, A1 class non-flammability, non-explosivity, and non-toxicity, non-explosivity they have been used in open systems (consumed when used) like fire extinguishers, inhalers, computer rooms fire extinguishing and insulation, etc.) since 1928.

History

[edit]



The observed stabilization of HCFC concentrations (left graphs) and the growth of HFCs (right graphs) in earth's atmosphere.

The first air conditioners and refrigerators employed toxic or flammable gases, such as ammonia, sulfur dioxide, methyl chloride, or propane, that could result in fatal accidents when they leaked.^[4]

In 1928 Thomas Midgley Jr. created the first non-flammable, non-toxic chlorofluorocarbon gas, *Freon* (R-12). The name is a trademark name owned by DuPont (now Chemours) for any chlorofluorocarbon (CFC), hydrochlorofluorocarbon (HCFC), or hydrofluorocarbon (HFC) refrigerant. Following the discovery of better synthesis methods, CFCs such as R-11,^[5] R-12,^[6] R-123^[5] and R-502^[7] dominated the market.

Phasing out of CFCs

[edit]

See also: Montreal Protocol

In the mid-1970s, scientists discovered that CFCs were causing major damage to the ozone layer that protects the earth from ultraviolet radiation, and to the ozone holes over polar regions.^{[8][9]} This led to the signing of the Montreal Protocol in 1987 which aimed to phase out CFCs and HCFC^[10] but did not address the contributions that HFCs made to climate change. The adoption of HCFCs such as R-22,^{[11][12][13]} and R-123^[5] was accelerated and so were used in most U.S. homes in air conditioners and in chillers^[14] from the 1980s as they have a dramatically lower Ozone Depletion Potential (ODP) than CFCs, but their ODP was still not zero which led to their eventual phase-out.

Hydrofluorocarbons (HFCs) such as R-134a,^{[15][16]} R-407A,^[17] R-407C,^[18] R-404A,^[7] R-410A^[19] (a 50/50 blend of R-125/R-32) and R-507^{[20][21]} were promoted as replacements for CFCs and HCFCs in the 1990s and 2000s. HFCs were not ozone-depleting but did have global warming potentials (GWPs) thousands of times greater than CO₂ with atmospheric lifetimes that can extend for decades. This in turn, starting from the 2010s, led to the adoption in new equipment of Hydrocarbon and HFO (hydrofluoroolefin) refrigerants R-32,^[22] R-290,^[23] R-600a,^[23] R-454B,^[24] R-1234yf,^{[25][26]} R-514A,^[27] R-744 (CO₂),^[28] R-1234ze(E)^[29] and R-1233zd(E),^[30] which have both an ODP of zero and a lower GWP. Hydrocarbons and CO₂ are sometimes called natural refrigerants because they can be found in nature.

The environmental organization Greenpeace provided funding to a former East German refrigerator company to research alternative ozone- and climate-safe refrigerants in 1992. The company developed a hydrocarbon mixture of propane and isobutane, or pure isobutane,^[31] called "Greenfreeze", but as a condition of the contract with Greenpeace could not patent the technology, which led to widespread adoption by other firms.^{[32][33][34]} Policy and political influence by corporate executives resisted change however,^{[35][36]} citing the flammability and explosive properties of the refrigerants,^[37] and DuPont together with other companies blocked them in the U.S. with the U.S. EPA.^{[38][39]}

Beginning on 14 November 1994, the U.S. Environmental Protection Agency restricted the sale, possession and use of refrigerants to only licensed technicians, per rules under sections 608 and 609 of the Clean Air Act.^[40] In 1995, Germany made CFC refrigerators illegal.^[41]

In 1996 Eurammon, a European non-profit initiative for natural refrigerants, was established and comprises European companies, institutions, and industry experts.^{[42][43][44]}

In 1997, FCs and HFCs were included in the Kyoto Protocol to the Framework Convention on Climate Change.

In 2000 in the UK, the Ozone Regulations^[45] came into force which banned the use of ozone-depleting HCFC refrigerants such as R22 in new systems. The Regulation banned the use of R22 as a "top-up" fluid for maintenance from 2010 for virgin fluid and from 2015 for recycled fluid.^[citation needed]

Addressing greenhouse gases

[edit]

With growing interest in natural refrigerants as alternatives to synthetic refrigerants such as CFCs, HCFCs and HFCs, in 2004, Greenpeace worked with multinational corporations like Coca-Cola and Unilever, and later Pepsico and others, to create a corporate coalition called Refrigerants Naturally!.^[41]^[46] Four years later, Ben & Jerry's of Unilever and General Electric began to take steps to support production and use in the U.S.^[47] It is estimated that almost 75 percent of the refrigeration and air conditioning sector has the potential to be converted to natural refrigerants.^[48]

In 2006, the EU adopted a Regulation on fluorinated greenhouse gases (FCs and HFCs) to encourage to transition to natural refrigerants (such as hydrocarbons). It was reported in 2010 that some refrigerants are being used as recreational drugs, leading to an extremely dangerous phenomenon known as inhalant abuse.^[49]

From 2011 the European Union started to phase out refrigerants with a global warming potential (GWP) of more than 150 in automotive air conditioning (GWP = 100-year warming potential of one kilogram of a gas relative to one kilogram of CO₂) such as the refrigerant HFC-134a (known as R-134a in North America) which has a GWP of 1526.^[50] In the same year the EPA decided in favour of the ozone- and climate-safe refrigerant for U.S. manufacture.^[32]^[51]^[52]

A 2018 study by the nonprofit organization "Drawdown" put proper refrigerant management and disposal at the very top of the list of climate impact solutions, with an impact equivalent to eliminating over 17 years of US carbon dioxide emissions.^[53]

In 2019 it was estimated that CFCs, HCFCs, and HFCs were responsible for about 10% of direct radiative forcing from all long-lived anthropogenic greenhouse gases.^[54] and in the same year the UNEP published new voluntary guidelines,^[55] however many countries have not yet ratified the Kigali Amendment.

From early 2020 HFCs (including R-404A, R-134a and R-410A) are being superseded: Residential air-conditioning systems and heat pumps are increasingly using R-32. This still has a GWP of more than 600. Progressive devices use refrigerants with almost no climate impact, namely R-290 (propane), R-600a (isobutane) or R-1234yf (less flammable, in cars). In commercial refrigeration also CO₂ (R-744) can be used.

Requirements and desirable properties

[edit]

A refrigerant needs to have: a boiling point that is somewhat below the target temperature (although boiling point can be adjusted by adjusting the pressure appropriately), a high heat of vaporization, a moderate density in liquid form, a relatively high density in gaseous form (which can also be adjusted by setting pressure appropriately), and a high critical temperature. Working pressures should ideally be containable by copper tubing, a commonly available material. Extremely high pressures should be avoided.^[citation needed]

The ideal refrigerant would be: non-corrosive, non-toxic, non-flammable, with no ozone depletion and global warming potential. It should preferably be natural with well-studied and low environmental impact. Newer refrigerants address the issue of the damage that CFCs caused to the ozone layer and the contribution that HCFCs make to climate change, but some do raise issues relating to toxicity and/or flammability.^[56]

Common refrigerants

[edit]

Refrigerants with very low climate impact

[edit]

With increasing regulations, refrigerants with a very low global warming potential are expected to play a dominant role in the 21st century,^[57] in particular, R-290 and R-1234yf. Starting from almost no market share in 2018,^[58] low GWPO devices are gaining market share in 2022.

Code	Chemical	Name	GWP		Status	Commentary
			20yr ^[59]	100yr ^[59]		

R-290	C_3H_8	Propane		3.3[60]	Increasing use	Low cost, widely available and efficient. They also have zero ozone depletion potential. Despite their flammability, they are increasingly used in domestic refrigerators and heat pumps. In 2010, about one-third of all household refrigerators and freezers manufactured globally used isobutane or an isobutane/propane blend, and this was expected to increase to 75% by 2020.[61]
R-600a	$HC(CH_3)_3$	Isobutane		3.3	Widely used	See R-290. Commonly used before the popularisation of CFCs, it is again being considered but does suffer from the disadvantage of toxicity, and it requires corrosion-resistant components, which restricts its domestic and small-scale use. Anhydrous ammonia is widely used in industrial refrigeration applications and hockey rinks because of its high energy efficiency and low cost.
R-717	NH_3	Ammonia	0	0[62]	Widely used	Less performance but also less flammable than R-290.[57] GM announced that it would start using "hydro-fluoro olefin", HFO-1234yf, in all of its brands by 2013.[63]
R-1234yf HFO-1234yf	$C_3H_2F_4$	2,3,3,3-Tetrafluoropropene		<1		

R-744	CO ₂	Carbon dioxide	1	1	In use
-------	-----------------	----------------	---	---	--------

Was used as a refrigerant prior to the discovery of CFCs (this was also the case for propane)^[4] and now having a renaissance due to it being non-ozone depleting, non-toxic and non-flammable. It may become the working fluid of choice to replace current HFCs in cars, supermarkets, and heat pumps. Coca-Cola has fielded CO₂-based beverage coolers and the U.S. Army is considering CO₂ refrigeration.^{[64][65]} Due to the need to operate at pressures of up to 130 bars (1,900 psi; 13,000 kPa), CO₂ systems require highly resistant components, however these have already been developed for mass production in many sectors.

Most used

[edit]

Code	Chemical	Name	Global warming potential 20yr ^[59]	GWP 100yr ^[59]	Status	Commentary
------	----------	------	---	---------------------------	--------	------------

R-32 HFC-32	CH ₂ F ₂	Difluoromethane	2430	677	Widely used	Promoted as climate-friendly substitute for R-134a and R-410A, but still with high climate impact. Has excellent heat transfer and pressure drop performance, both in condensation and vaporisation. ^[66] It has an atmospheric lifetime of nearly 5 years. ^[67] Currently used in residential and commercial air-conditioners and heat pumps.
R-134a HFC-134a	CH ₂ FCF ₃	1,1,1,2-Tetrafluoroethane	3790	1550	Widely used	Most used in 2020 for hydronic heat pumps in Europe and the United States in spite of high GWP. ^[58] Commonly used in automotive air conditioners prior to phase out which began in 2012.
R-410A		50% R-32 / 50% R-125 (pentafluoroethane)	Between 2430 (R-32) and 6350 (R-125)	> 677	Widely Used	Most used in split heat pumps / AC by 2018. Almost 100% share in the USA. ^[58] Being phased out in the US starting in 2022. ^{[68][69]}

Banned / Phased out

[edit]

Code	Chemical	Name	Global warming potential 20yr ^[59]	GWP 100yr ^[59]	Status	Commentary
R-11 CFC-11	CCl ₃ F	Trichlorofluoromethane	6900	4660	Banned	Production was banned in developed countries by Montreal Protocol in 1996

R-12 CFC-12	CCl_2F_2	Dichlorodifluoromethane	10800	10200	Banned	Also known as Freon, a widely used chlorofluorocarbon halomethane (CFC). Production was banned in developed countries by Montreal Protocol in 1996, and in developing countries (article 5 countries) in 2010. ^[70] A widely used hydrochlorofluorocarbon (HCFC) and powerful greenhouse gas with a GWP equal to 1810.
R-22 HCFC-22	CHClF_2	Chlorodifluoromethane	5280	1760	Being phased out	Worldwide production of R-22 in 2008 was about 800 Gg per year, up from about 450 Gg per year in 1998. R-438A (MO-99) is a R-22 replacement. ^[71] Used in large tonnage centrifugal chiller applications. All U.S. production and import of virgin HCFCs will be phased out by 2030, with limited exceptions. ^[72]
R-123 HCFC-123	CHCl_2CF_3	2,2-Dichloro-1,1,1-trifluoroethane	292	79	US phase-out	R-123 refrigerant was used to retrofit some chiller that used R-11 refrigerant Trichlorofluoromethane. The production of R-11 was banned in developed countries by Montreal Protocol in 1996. ^[73]

Other

[edit]

Code	Chemical	Name	Global warming potential 20yr ^[59]	GWP 100yr ^[59]	Commentary
R-152a HFC-152a	CH ₃ CHF ₂	1,1-Difluoroethane	506	138	As a compressed air duster
R-407C		Mixture of difluoromethane and pentafluoroethane and 1,1,1,2-tetrafluoroethane			A mixture of R-32, R-125, and R-134a
R-454B		Difluoromethane and 2,3,3,3-Tetrafluoropropene			HFOs blend of refrigerants Difluoromethane (R-32) and 2,3,3,3-Tetrafluoropropene (R-1234yf). ^{[74][75][76][77]}
R-513A		An HFO/HFC blend (56% R-1234yf/44%R-134a)			May replace R-134a as an interim alternative ^[78]
R-514A		HFO-1336mzz-Z/trans-1,2-dichloroethylene (t-DCE)			An hydrofluoroolefin (HFO)-based refrigerant to replace R-123 in low pressure centrifugal chillers for commercial and industrial applications. ^{[79][80]}

Refrigerant reclamation and disposal

[edit]

Main article: Refrigerant reclamation


Coolant and refrigerants are found throughout the industrialized world, in homes, offices, and factories, in devices such as refrigerators, air conditioners, central air conditioning systems (HVAC), freezers, and dehumidifiers. When these units are serviced, there is a risk that refrigerant gas will be vented into the atmosphere either accidentally or intentionally, hence the creation of technician training and certification programs in order to ensure that the material is conserved and managed safely. Mistreatment of these gases has been shown to deplete the ozone layer and is suspected to contribute to global warming.^[81]

With the exception of isobutane and propane (R600a, R441A and R290), ammonia and CO₂ under Section 608 of the United States' Clean Air Act it is illegal to knowingly release any refrigerants into the atmosphere.^{[82][83]}

Refrigerant reclamation is the act of processing used refrigerant gas which has previously been used in some type of refrigeration loop such that it meets specifications for new refrigerant gas. In the United States, the Clean Air Act of 1990 requires that used refrigerant be processed by a certified reclaimer, which must be licensed by the United States Environmental Protection Agency (EPA), and the material must be recovered and delivered to the reclaimer by EPA-certified technicians.^[84]

Classification of refrigerants

[edit]



R407C pressure-enthalpy diagram, isotherms between the two saturation lines

Main article: List of refrigerants

Refrigerants may be divided into three classes according to their manner of absorption or extraction of heat from the substances to be refrigerated:^[*citation needed*]

- Class 1: This class includes refrigerants that cool by phase change (typically boiling), using the refrigerant's latent heat.
- Class 2: These refrigerants cool by temperature change or 'sensible heat', the quantity of heat being the specific heat capacity x the temperature change. They are air, calcium chloride brine, sodium chloride brine, alcohol, and similar nonfreezing solutions. The purpose of Class 2 refrigerants is to receive a reduction of temperature from Class 1 refrigerants and convey this lower temperature to the area to be cooled.
- Class 3: This group consists of solutions that contain absorbed vapors of liquefiable agents or refrigerating media. These solutions function by nature of their ability to carry liquefiable vapors, which produce a cooling effect by the absorption of their heat of solution. They can also be classified into many categories.

R numbering system

[edit]

The R- numbering system was developed by DuPont (which owned the Freon trademark), and systematically identifies the molecular structure of refrigerants made with a single halogenated hydrocarbon. ASHRAE has since set guidelines for the numbering system as follows:[⁸⁵]

R- $X_1X_2X_3X_4$

- X_1 = Number of unsaturated carbon-carbon bonds (omit if zero)
- X_2 = Number of carbon atoms minus 1 (omit if zero)
- X_3 = Number of hydrogen atoms plus 1
- X_4 = Number of fluorine atoms

Series

[edit]

- **R-xx** Methane Series
- **R-1xx** Ethane Series
- **R-2xx** Propane Series
- **R-4xx** Zeotropic blend
- **R-5xx** Azeotropic blend
- **R-6xx** Saturated hydrocarbons (except for propane which is R-290)
- **R-7xx** Inorganic Compounds with a molar mass < 100
- **R-7xxx** Inorganic Compounds with a molar mass > 100

Ethane Derived Chains

[edit]

- **Number Only** Most symmetrical isomer
- **Lower Case Suffix (a, b, c, etc.)** indicates increasingly unsymmetrical isomers

Propane Derived Chains

[edit]

- **Number Only** If only one isomer exists; otherwise:
- **First lower case suffix (a-f):**
 - **a Suffix** Cl₂ central carbon substitution
 - **b Suffix** Cl, F central carbon substitution
 - **c Suffix** F₂ central carbon substitution
 - **d Suffix** Cl, H central carbon substitution

- **e Suffix** F, H central carbon substitution
- **f Suffix** H₂ central carbon substitution
- **2nd Lower Case Suffix (a, b, c, etc.)** Indicates increasingly unsymmetrical isomers

Propene derivatives

[edit]

- **First lower case suffix (x, y, z):**
 - **x Suffix** Cl substitution on central atom
 - **y Suffix** F substitution on central atom
 - **z Suffix** H substitution on central atom
- **Second lower case suffix (a-f):**
 - **a Suffix** =CCl₂ methylene substitution
 - **b Suffix** =CClF methylene substitution
 - **c Suffix** =CF₂ methylene substitution
 - **d Suffix** =CHCl methylene substitution
 - **e Suffix** =CHF methylene substitution
 - **f Suffix** =CH₂ methylene substitution

Blends

[edit]

- **Upper Case Suffix (A, B, C, etc.)** Same blend with different compositions of refrigerants

Miscellaneous

[edit]

- **R-Cxxx** Cyclic compound
- **R-Exxx** Ether group is present
- **R-CExxx** Cyclic compound with an ether group
- **R-4xx/5xx + Upper Case Suffix (A, B, C, etc.)** Same blend with different composition of refrigerants
- **R-6xx + Lower Case Letter** Indicates increasingly unsymmetrical isomers
- **7xx/7xxx + Upper Case Letter** Same molar mass, different compound
- **R-xxxxB#** Bromine is present with the number after B indicating how many bromine atoms
- **R-xxxxI#** Iodine is present with the number after I indicating how many iodine atoms
- **R-xxx(E)** Trans Molecule
- **R-xxx(Z)** Cis Molecule

For example, R-134a has 2 carbon atoms, 2 hydrogen atoms, and 4 fluorine atoms, an empirical formula of tetrafluoroethane. The "a" suffix indicates that the isomer is unbalanced by one atom, giving 1,1,1,2-Tetrafluoroethane. R-134 (without the "a" suffix)

would have a molecular structure of 1,1,2,2-Tetrafluoroethane.

The same numbers are used with an R- prefix for generic refrigerants, with a "Propellant" prefix (e.g., "Propellant 12") for the same chemical used as a propellant for an aerosol spray, and with trade names for the compounds, such as "**Freon 12**". Recently, a practice of using abbreviations HFC- for hydrofluorocarbons, CFC- for chlorofluorocarbons, and HCFC- for hydrochlorofluorocarbons has arisen, because of the regulatory differences among these groups.^[*citation needed*]

Refrigerant safety

[edit]

ASHRAE Standard 34, *Designation and Safety Classification of Refrigerants*, assigns safety classifications to refrigerants based upon toxicity and flammability.

Using safety information provided by producers, ASHRAE assigns a capital letter to indicate toxicity and a number to indicate flammability. The letter "A" is the least toxic and the number 1 is the least flammable.^[⁸⁶]

See also

[edit]

- Brine (Refrigerant)
- Section 608
- List of Refrigerants

References

[edit]

- ¹ [^] *United Nations Environment Programme (UNEP)*. "Update on New Refrigerants Designations and Safety Classifications" (PDF). ASHRAE. Retrieved 6 October 2024.
- ² [^] "Phaseout of Class II Ozone-Depleting Substances". US Environmental Protection Agency. 22 July 2015. Retrieved October 6, 2024.
- ³ [^] "Protecting Our Climate by Reducing Use of HFCs". United States Environmental Protection Agency. 8 February 2021. Retrieved 6 October 2024.
- ⁴ [^] **a b** Pearson, S. *Forbes*. "Refrigerants Past, Present and Future" (PDF). R744. Archived from the original (PDF) on 2018-07-13. Retrieved 2021-03-30.
- ⁵ [^] **a b c** "Finally, a replacement for R123?". *Cooling Post*. 17 October 2013.
- ⁶ [^] https://asrjetsjournal.org/index.php/American_Scientific_Journal/article/download/3297/1244/
- ⁷ [^] **a b** Tomczyk, John (1 May 2017). "What's the Latest with R-404A?". *achrnews.com*.
- ⁸ [^] Molina, Mario J.; Rowland, F. S (28 June 1974). "Stratospheric sink for chlorofluoromethanes: chlorine catalysed destruction of ozone" (PDF). *Nature*. **249**: 810–812. doi:10.1038/249810a0. Retrieved October 6, 2024.

9. ^ National Research Council (1976). *Halocarbons: Effects on Stratospheric Ozone*. Washington, DC: The National Academies Press. doi:10.17226/19978. ISBN 978-0-309-02532-4. Retrieved October 6, 2024.
10. ^ "Air Conditioners, Dehumidifiers, and R-410A Refrigerant". *Sylvane*. 1 July 2011. Retrieved 27 July 2023.
11. ^ Protection, United States Congress Senate Committee on Environment and Public Works Subcommittee on Environmental (May 14, 1987). "Clean Air Act Amendments of 1987: Hearings Before the Subcommittee on Environmental Protection of the Committee on Environment and Public Works, United States Senate, One Hundredth Congress, First Session, on S. 300, S. 321, S. 1351, and S. 1384 ..." U.S. Government Printing Office – via Google Books.
12. ^ *Fluorinated Hydrocarbons—Advances in Research and Application* (2013 ed.). ScholarlyEditions. June 21, 2013. p. 179. ISBN 9781481675703 – via Google Books.
13. ^ Whitman, Bill; Johnson, Bill; Tomczyk, John; Silberstein, Eugene (February 25, 2008). *Refrigeration and Air Conditioning Technology*. Cengage Learning. p. 171. ISBN 978-1111803223 – via Google Books.
14. ^ "Scroll Chillers: Conversion from HCFC-22 to HFC-410A and HFC-407C" (PDF). Archived from the original (PDF) on 2021-07-20. Retrieved 2021-03-29.
15. ^ "What's Happening With R-134a? | 2017-06-05 | ACHRNEWS | ACHR News". *achrnews.com*.
16. ^ "Conversion R12/R134a" (PDF). Behr Hella Service GmbH. 1 October 2005. Retrieved 27 July 2023.
17. ^ "R-407A Gains SNAP OK". *achrnews.com* (Press release). 22 June 2009.
18. ^ "June 26, 2009: Emerson Approves R-407A, R-407C for Copeland Discus Compressors". *achrnews.com*.
19. ^ "Taking New Refrigerants to the Peak". *achrnews.com*.
20. ^ Koenig, H. (31 December 1995). "R502/R22 - replacement refrigerant R507 in commercial refrigeration; R502/R22 - Ersatzkaeltemittel R507 in der Gewerbekuehlung. Anwendungstechnik - Kaeltemittel".
21. ^ Linton, J. W.; Snelson, W. K.; Triebe, A. R.; Hearty, P. F. (31 December 1995). "System performance comparison of R-507 with R-502". OSTI 211821.
22. ^ "Daikin reveals details of R32 VRV air conditioner". *Cooling Post*. 6 February 2020.
23. ^ **a b** "Refrigerant blends to challenge hydrocarbon efficiencies". *Cooling Post*. 22 December 2019.
24. ^ "An HVAC Technician's Guide to R-454B". *achrnews.com*.
25. ^ "The truth about new automotive A/C refrigerant R1234YF". 25 July 2018.
26. ^ Kontomaris, Konstantinos (2014). "HFO-1336mzz-Z: High Temperature Chemical Stability and Use as A Working Fluid in Organic Rankine Cycles". *International Refrigeration and Air Conditioning Conference*. "Paper 1525"
27. ^ "Trane adopts new low GWP refrigerant R514A". *Cooling Post*. 15 June 2016.
28. ^ "R404A – the alternatives". *Cooling Post*. 26 February 2014.
29. ^ "Carrier expands R1234ze chiller range". *Cooling Post*. 20 May 2020.
30. ^ "Carrier confirms an HFO refrigerant future". *Cooling Post*. 5 June 2019.
31. ^ "Greenfreeze: A revolution in domestic refrigeration". *ecomall.com*. Retrieved 2022-07-04.

32. ^ **a b** "Happy birthday, Greenfreeze!". Greenpeace. 25 March 2013. Archived from the original on 2020-04-08. Retrieved 8 June 2015.
33. ^ "Ozone Secretariat". United Nations Environment Programme. Archived from the original on 12 April 2015.
34. ^ Gunkel, Christoph (13 September 2013). "Öko-Coup aus Ostdeutschland". *Der Spiegel* (in German). Retrieved 4 September 2015.
35. ^ Maté, John (2001). "Making a Difference: A Case Study of the Greenpeace Ozone Campaign". *Review of European Community & International Environmental Law*. **10** (2): 190–198. doi:10.1111/1467-9388.00275.
36. ^ Benedick, Richard Elliot Ozone Diplomacy Cambridge, MA: Harvard University 1991.
37. ^ Honeywell International, Inc. (2010-07-09). "Comment on EPA Proposed Rule Office of Air and Radiation Proposed Significant New Alternatives Policy (SNAP) Protection of Stratospheric Ozone: Listing of Substitutes for Ozone-Depleting Substances – Hydrocarbon Refrigerants" (PDF).
38. ^ "Discurso de Frank Guggenheim no lançamento do Greenfreeze | Brasil". Greenpeace.org. Archived from the original on 24 September 2015. Retrieved 10 June 2015.
39. ^ "Der Greenfreeze - endlich in den USA angekommen". Greenpeace.de (in German). 28 December 2011. Retrieved 10 June 2015.
40. ^ "Complying With The Section 608 Refrigerant Recycling Rule | Ozone Layer Protection - Regulatory Programs". Epa.gov. 21 April 2015. Retrieved 10 June 2015.
41. ^ **a b** "Greenfreeze: a Revolution in Domestic Refrigeration". ecomall.com. Retrieved 8 June 2015.
42. ^ "Company background". Archived from the original on 2020-02-20. Retrieved 2021-03-15.
43. ^ Safeguarding the ozone layer and the global climate System: issues related to Hydrofluorocarbons and Perfluorocarbons (Report). IPCC/TEAP. 2005.
44. ^ Crowley, Thomas J. (2000). "Causes of Climate Change over the Past 1000 Years". *Science*. **289** (5477): 270–277. Bibcode:2000Sci...289..270C. doi:10.1126/science.289.5477.270. PMID 10894770.
45. ^ "2010 to 2015 government policy: environmental quality". GOV.UK. 8 May 2015. Retrieved 10 June 2015.
46. ^ "PepsiCo Brings First Climate-Friendly Vending Machines to the U.S.". phx.corporate-ir.net. Retrieved 8 June 2015.
47. ^ "Climate-Friendly Greenfreezers Come to the United States". WNBC. 2 October 2008. Retrieved 8 June 2015.
48. ^ Data, Reports and (7 August 2020). "Natural Refrigerants Market To Reach USD 2.88 Billion By 2027 | Reports and Data". GlobeNewswire News Room (Press release). Retrieved 17 December 2020.
49. ^ Harris, Catharine. "Anti-inhalant Abuse Campaign Targets Building Codes: 'Huffing' of Air Conditioning Refrigerant a Dangerous Risk." The Nation's Health. American Public Health Association, 2010. Web. 5 December 2010. <https://www.thenationshealth.org/content/39/4/20>
50. ^ IPCC AR6 WG1 Ch7 2021
51. ^ "GreenFreeze". Greenpeace.

52. ^ "Significant New Alternatives Program: Substitutes in Household Refrigerators and Freezers". *Epa.gov*. 13 November 2014. Retrieved 4 June 2018.
53. ^ Berwald, Juli (29 April 2019). "One overlooked way to fight climate change? Dispose of old CFCs". *National Geographic - Environment*. Archived from the original on April 29, 2019. Retrieved 30 April 2019.
54. ^ Butler J. and Montzka S. (2020). "The NOAA Annual Greenhouse Gas Index (AGGI)". NOAA Global Monitoring Laboratory/Earth System Research Laboratories.
55. ^ Environment, U. N. (31 October 2019). "New guidelines for air conditioners and refrigerators set to tackle climate change". *UN Environment*. Retrieved 30 March 2020.
56. ^ Rosenthal, Elisabeth; Lehren, Andrew (20 June 2011). "Relief in Every Window, but Global Worry Too". *The New York Times*. Retrieved 21 June 2012.
57. ^ **a b** Yadav et al 2022
58. ^ **a b c** BSRIA 2020
59. ^ **a b c d e f g h** IPCC AR5 WG1 Ch8 2013, pp. 714, 731–737
60. ^ "European Commission on retrofit refrigerants for stationary applications" (PDF). Archived from the original on August 5, 2009. Retrieved 2010-10-29.cite web: CS1 maint: unfit URL (link)
61. ^ "Protection of Stratospheric Ozone: Hydrocarbon Refrigerants" (PDF). *Environment Protection Agency*. Retrieved 5 August 2018.
62. ^ ARB 2022
63. ^ GM to Introduce HFO-1234yf AC Refrigerant in 2013 US Models
64. ^ "The Coca-Cola Company Announces Adoption of HFC-Free Insulation in Refrigeration Units to Combat Global Warming". *The Coca-Cola Company*. 5 June 2006. Archived from the original on 1 November 2013. Retrieved 11 October 2007.
65. ^ "Modine reinforces its CO₂ research efforts". *R744.com*. 28 June 2007. Archived from the original on 10 February 2008.
66. ^ Longo, Giovanni A.; Mancin, Simone; Righetti, Giulia; Zilio, Claudio (2015). "HFC32 vaporisation inside a Brazed Plate Heat Exchanger (BPHE): Experimental measurements and IR thermography analysis". *International Journal of Refrigeration*. **57**: 77–86. doi:10.1016/j.ijrefrig.2015.04.017.
67. ^ May 2010 TEAP XXI/9 Task Force Report
68. ^ "Protecting Our Climate by Reducing Use of HFCs". *US Environmental Protection Agency*. 8 February 2021. Retrieved 25 August 2022.
69. ^ "Background on HFCs and the AIM Act". *www.usepa.gov*. *US EPA*. March 2021. Retrieved 27 June 2024.
70. ^ "1:Update on Ozone-Depleting Substances (ODSs) and Other Gases of Interest to the Montreal Protocol". *Scientific assessment of ozone depletion: 2018 (PDF) (Global Ozone Research and Monitoring Project–Report No. 58 ed.)*. Geneva, Switzerland: *World Meteorological Organization*. 2018. p. 1.10. ISBN 978-1-7329317-1-8. Retrieved 22 November 2020.
71. ^ [1] Chemours M099 as R22 Replacement
72. ^ [2] Management of HCFC-123 through the Phaseout and Beyond | EPA | Published August 2020 | Retrieved Dec. 18, 2021
73. ^ [3] Refrigerant R11 (R-11), Freon 11 (Freon R-11) Properties & Replacement
74. ^ [4] R-454B XL41 refrigerant fact & info sheet

75. ^ [5] R-454B emerges as a replacement for R-410A | ACHR News (Air Conditioning, Heating, Refrigeration News)
76. ^ [6] Carrier introduces [R-454B] Puron Advance™ as the next generation refrigerant for ducted residential, light commercial products in North America | Indianapolis - 19 December 2018
77. ^ [7] Johnson Controls selects R-454B as future refrigerant for new HVAC equipment | 27 May 2021
78. ^ [8] A conversation on refrigerants | ASHRAE Journal, March 2021 | page 30, column 1, paragraph 2
79. ^ [9] Opteon™ XP30 (R-514A) refrigerant
80. ^ [10] Trane adopts new low GWP refrigerant R514A | 15 June 2016
81. ^ "Emissions of Greenhouse Gases in the United States 1998 - Executive Summary". 18 August 2000. Archived from the original on 18 August 2000.
82. ^ "Frequently Asked Questions on Section 608". Environment Protection Agency. Retrieved 20 December 2013.
83. ^ "US hydrocarbons". Retrieved 5 August 2018.
84. ^ "42 U.S. Code § 7671g - National recycling and emission reduction program". LII / Legal Information Institute.
85. ^ ASHRAE; UNEP (Nov 2022). "Designation and Safety Classification of Refrigerants" (PDF). ASHRAE. Retrieved 1 July 2023.
86. ^ "Update on New Refrigerants Designations and Safety Classifications" (PDF). American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). April 2020. Archived from the original (PDF) on February 13, 2023. Retrieved October 22, 2022.

Sources

[edit]

IPCC reports

[edit]

- IPCC (2013). Stocker, T. F.; Qin, D.; Plattner, G.-K.; Tignor, M.; et al. (eds.). *Climate Change 2013: The Physical Science Basis (PDF). Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*. Cambridge, United Kingdom and New York, NY, USA: Cambridge University Press. ISBN 978-1-107-05799-9. (pb: 978-1-107-66182-0). Fifth Assessment Report - Climate Change 2013
 - Myhre, G.; Shindell, D.; Bréon, F.-M.; Collins, W.; et al. (2013). "Chapter 8: Anthropogenic and Natural Radiative Forcing" (PDF). *Climate Change 2013: The Physical Science Basis. Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*. pp. 659–740.

- IPCC (2021). Masson-Delmotte, V.; Zhai, P.; Pirani, A.; Connors, S. L.; et al. (eds.). *Climate Change 2021: The Physical Science Basis (PDF). Contribution of Working Group I to the Sixth Assessment Report of the Intergovernmental Panel on Climate Change. Cambridge University Press (In Press).*
- Forster, Piers; Storelvmo, Trude (2021). "Chapter 7: The Earth's Energy Budget, Climate Feedbacks, and Climate Sensitivity" (PDF). IPCC AR6 WG1 2021.

Other

[edit]

- "High GWP refrigerants". California Air Resources Board. Retrieved 13 February 2022 .
- "BSRIA's view on refrigerant trends in AC and Heat Pump segments". 2020. Retrieved 2022-02-14.
- Yadav, Saurabh; Liu, Jie; Kim, Sung Chul (2022). "A comprehensive study on 21st-century refrigerants - R290 and R1234yf: A review". *International Journal of Heat and Mass Transfer*. **122**: 121947. Bibcode:2022IJHMT.18221947Y. doi:10.1016/j.ijheatmasstransfer.2021.121947. S2CID 240534198.

External links

[edit]

- US Environmental Protection Agency page on the GWPs of various substances
 - Green Cooling Initiative on alternative natural refrigerants cooling technologies
 - International Institute of Refrigeration Archived 2018-09-25 at the Wayback Machine
 - v
 - t
 - e
- Heating, ventilation, and air conditioning

**Fundamental
concepts**

- Air changes per hour
- Bake-out
- Building envelope
- Convection
- Dilution
- Domestic energy consumption
- Enthalpy
- Fluid dynamics
- Gas compressor
- Heat pump and refrigeration cycle
- Heat transfer
- Humidity
- Infiltration
- Latent heat
- Noise control
- Outgassing
- Particulates
- Psychrometrics
- Sensible heat
- Stack effect
- Thermal comfort
- Thermal destratification
- Thermal mass
- Thermodynamics
- Vapour pressure of water

Technology

- Absorption-compression heat pump
- Absorption refrigerator
- Air barrier
- Air conditioning
- Antifreeze
- Automobile air conditioning
- Autonomous building
- Building insulation materials
- Central heating
- Central solar heating
- Chilled beam
- Chilled water
- Constant air volume (CAV)
- Coolant
- Cross ventilation
- Dedicated outdoor air system (DOAS)
- Deep water source cooling
- Demand controlled ventilation (DCV)
- Displacement ventilation
- District cooling
- District heating
- Electric heating
- Energy recovery ventilation (ERV)
- Firestop
- Forced-air
- Forced-air gas
- Free cooling
- Heat recovery ventilation (HRV)
- Hybrid heat
- Hydronics
- Ice storage air conditioning
- Kitchen ventilation
- Mixed-mode ventilation
- Microgeneration
- Passive cooling
- Passive daytime radiative cooling
- Passive house
- Passive ventilation
- Radiant heating and cooling
- Radiant cooling
- Radiant heating
- Radon mitigation
- Refrigeration
- Renewable heat
- Room air distribution
- Solar air heat
- Solar combisystem
- Solar cooling
- Solar heating
- Thermal insulation

- Air conditioner inverter
- Air door
- Air filter
- Air handler
- Air ionizer
- Air-mixing plenum
- Air purifier
- Air source heat pump
- Attic fan
- Automatic balancing valve
- Back boiler
- Barrier pipe
- Blast damper
- Boiler
- Centrifugal fan
- Ceramic heater
- Chiller
- Condensate pump
- Condenser
- Condensing boiler
- Convection heater
- Compressor
- Cooling tower
- Damper
- Dehumidifier
- Duct
- Economizer
- Electrostatic precipitator
- Evaporative cooler
- Evaporator
- Exhaust hood
- Expansion tank
- Fan
- Fan coil unit
- Fan filter unit
- Fan heater
- Fire damper
- Fireplace
- Fireplace insert
- Freeze stat
- Flue
- Freon
- Fume hood
- Furnace
- Gas compressor
- Gas heater
- Gasoline heater
- Grease duct
- Grille
- Ground-coupled heat exchanger

Components

**Measurement
and control**

- Air flow meter
- Aquastat
- BACnet
- Blower door
- Building automation
- Carbon dioxide sensor
- Clean air delivery rate (CADR)
- Control valve
- Gas detector
- Home energy monitor
- Humidistat
- HVAC control system
- Infrared thermometer
- Intelligent buildings
- LonWorks
- Minimum efficiency reporting value (MERV)
- Normal temperature and pressure (NTP)
- OpenTherm
- Programmable communicating thermostat
- Programmable thermostat
- Psychrometrics
- Room temperature
- Smart thermostat
- Standard temperature and pressure (STP)
- Thermographic camera
- Thermostat
- Thermostatic radiator valve
- Architectural acoustics
- Architectural engineering
- Architectural technologist
- Building services engineering
- Building information modeling (BIM)
- Deep energy retrofit
- Duct cleaning
- Duct leakage testing
- Environmental engineering
- Hydronic balancing
- Kitchen exhaust cleaning
- Mechanical engineering
- Mechanical, electrical, and plumbing
- Mold growth, assessment, and remediation
- Refrigerant reclamation
- Testing, adjusting, balancing

**Professions,
trades,
and services**

Industry organizations

- AHRI
- AMCA
- ASHRAE
- ASTM International
- BRE
- BSRIA
- CIBSE
- Institute of Refrigeration
- IIR
- LEED
- SMACNA
- UMC
- Indoor air quality (IAQ)
- Passive smoking
- Sick building syndrome (SBS)
- Volatile organic compound (VOC)
- ASHRAE Handbook
- Building science
- Fireproofing
- Glossary of HVAC terms
- Warm Spaces
- World Refrigeration Day
- Template:Home automation
- Template:Solar energy

Health and safety

See also

- United States
- France
- Japan
- Israel

Authority control databases: National      **Edit this at Wikidata**

About Prefabrication

Not to be confused with Preproduction.

"Prefab" redirects here. For other uses, see Prefab (disambiguation).

This article **needs additional citations for verification**. Please help improve this article by adding citations to reliable sources. Unsourced material may be challenged and removed.



Find sources: "Prefabrication" – news · newspapers · books · scholar · JSTOR (September 2014) *(Learn how and when to remove this message)*


Prefabrication is the practice of assembling components of a structure in a factory or other manufacturing site, and transporting complete assemblies or sub-assemblies to the construction site where the structure is to be located. Some researchers refer it to “various materials joined together to form a component of the final installation procedure“.

The most commonly cited definition is by Goodier and Gibb in 2007, which described the process of manufacturing and preassembly of a certain number of building components, modules, and elements before their shipment and installation on construction sites.^[1]

The term *prefabrication* also applies to the manufacturing of things other than structures at a fixed site. It is frequently used when fabrication of a section of a machine or any movable structure is shifted from the main manufacturing site to another location, and the section is supplied assembled and ready to fit. It is not generally used to refer to electrical or electronic components of a machine, or mechanical parts such as pumps, gearboxes and compressors which are usually supplied as separate items, but to sections of the body of the machine which in the past were fabricated with the whole machine. Prefabricated parts of the body of the machine may be called 'sub-assemblies' to distinguish them from the other components.

Process and theory

[edit]



Levittown, Puerto Rico


An example from house-building illustrates the process of prefabrication. The conventional method of building a house is to transport bricks, timber, cement, sand, steel and construction aggregate, etc. to the site, and to construct the house on site from these materials. In prefabricated construction, only the foundations are constructed in this way, while sections of walls, floors and roof are prefabricated (assembled) in a factory (possibly with window and door frames included), transported to the site, lifted into place by a crane and bolted together.

Prefabrication is used in the manufacture of ships, aircraft and all kinds of vehicles and machines where sections previously assembled at the final point of manufacture are assembled elsewhere instead, before being delivered for final assembly.

The theory behind the method is that time and cost is saved if similar construction tasks can be grouped, and assembly line techniques can be employed in prefabrication at a location where skilled labour is available, while congestion at the assembly site, which wastes time, can be reduced. The method finds application particularly where the structure is composed of repeating units or forms, or where multiple copies of the same basic structure are being constructed. Prefabrication avoids the need to transport so many skilled workers to the construction site, and other restricting conditions such as a lack of power, lack of water, exposure to harsh weather or a hazardous environment are avoided. Against these advantages must be weighed the cost of transporting prefabricated sections and lifting them into position as they will usually be larger, more fragile and more difficult to handle than the materials and components of which they are made.

History

[edit]



"Loren" Iron House, at Old Gipps town in Moe, Australia

Prefabrication has been used since ancient times. For example, it is claimed that the world's oldest known engineered roadway, the Sweet Track constructed in England around 3800 BC, employed prefabricated timber sections brought to the site rather than assembled on-site.^[*citation needed*]

Sinhalese kings of ancient Sri Lanka have used prefabricated buildings technology to erect giant structures, which dates back as far as 2000 years, where some sections were prepared separately and then fitted together, specially in the Kingdom of Anuradhapura and Polonnaruwa.

After the great Lisbon earthquake of 1755, the Portuguese capital, especially the Baixa district, was rebuilt by using prefabrication on an unprecedented scale. Under the guidance of Sebastião José de Carvalho e Melo, popularly known as the Marquis de Pombal, the

most powerful royal minister of D. Jose I, a new Pombaline style of architecture and urban planning arose, which introduced early anti-seismic design features and innovative prefabricated construction methods, according to which large multistory buildings were entirely manufactured outside the city, transported in pieces and then assembled on site. The process, which lasted into the nineteenth century, lodged the city's residents in safe new structures unheard-of before the quake.

Also in Portugal, the town of Vila Real de Santo António in the Algarve, founded on 30 December 1773, was quickly erected through the use of prefabricated materials en masse. The first of the prefabricated stones was laid in March 1774. By 13 May 1776, the centre of the town had been finished and was officially opened.

In 19th century Australia a large number of prefabricated houses were imported from the United Kingdom.


The method was widely used in the construction of prefabricated housing in the 20th century, such as in the United Kingdom as temporary housing for thousands of urban families "bombed out" during World War II. Assembling sections in factories saved time on-site and the lightness of the panels reduced the cost of foundations and assembly on site. Coloured concrete grey and with flat roofs, prefab houses were uninsulated and cold and life in a prefab acquired a certain stigma, but some London prefabs were occupied for much longer than the projected 10 years.^[2]

The Crystal Palace, erected in London in 1851, was a highly visible example of iron and glass prefabricated construction; it was followed on a smaller scale by Oxford Rewley Road railway station.

During World War II, prefabricated Cargo ships, designed to quickly replace ships sunk by Nazi U-boats became increasingly common. The most ubiquitous of these ships was the American Liberty ship, which reached production of over 2,000 units, averaging 3 per day.

Current uses

[edit]



A house being built with prefabricated concrete panels.

The most widely used form of prefabrication in building and civil engineering is the use of prefabricated concrete and prefabricated steel sections in structures where a particular part or form is repeated many times. It can be difficult to construct the formwork required to mould concrete components on site, and delivering wet concrete to the site before it starts to set requires precise time management. Pouring concrete sections in a factory brings the advantages of being able to re-use moulds and the concrete can be mixed on the spot without having to be transported to and pumped wet on a congested construction site. Prefabricating steel sections reduces on-site cutting and welding costs as well as the associated hazards.


Prefabrication techniques are used in the construction of apartment blocks, and housing developments with repeated housing units. Prefabrication is an essential part of the industrialization of construction.^[3] The quality of prefabricated housing units had increased to the point that they may not be distinguishable from traditionally built units to those that live in them. The technique is also used in office blocks, warehouses and factory buildings. Prefabricated steel and glass sections are widely used for the exterior of large buildings.

Detached houses, cottages, log cabin, saunas, etc. are also sold with prefabricated elements. Prefabrication of modular wall elements allows building of complex thermal insulation, window frame components, etc. on an assembly line, which tends to improve quality over on-site construction of each individual wall or frame. Wood construction in particular benefits from the improved quality. However, tradition often favors building by hand in many countries, and the image of prefab as a "cheap" method only slows its adoption. However, current practice already allows the modifying the floor plan according to the customer's requirements and selecting the surfacing material, e.g. a personalized brick facade can be masoned even if the load-supporting elements are timber.

Today, prefabrication is used in various industries and construction sectors such as healthcare, retail, hospitality, education, and public administration, due to its many advantages and benefits over traditional on-site construction, such as reduced installation time and cost savings.^[4] Being used in single-story buildings as well as in multi-story

projects and constructions. Providing the possibility of applying it to a specific part of the project or to the whole of it.

The efficiency and speed in the execution times of these works offer that, for example, in the case of the educational sector, it is possible to execute the projects without the cessation of the operations of the educational facilities during the development of the same.



Transportation of prefabricated Airbus wing assembly

Prefabrication saves engineering time on the construction site in civil engineering projects. This can be vital to the success of projects such as bridges and avalanche galleries, where weather conditions may only allow brief periods of construction. Prefabricated bridge elements and systems offer bridge designers and contractors significant advantages in terms of construction time, safety, environmental impact, constructibility, and cost. Prefabrication can also help minimize the impact on traffic from bridge building. Additionally, small, commonly used structures such as concrete pylons are in most cases prefabricated.

Radio towers for mobile phone and other services often consist of multiple prefabricated sections. Modern lattice towers and guyed masts are also commonly assembled of prefabricated elements.

Prefabrication has become widely used in the assembly of aircraft and spacecraft, with components such as wings and fuselage sections often being manufactured in different countries or states from the final assembly site. However, this is sometimes for political rather than commercial reasons, such as for Airbus.

Advantages

[edit]

- Moving partial assemblies from a factory often costs less than moving pre-production resources to each site

- Deploying resources on-site can add costs; prefabricating assemblies can save costs by reducing on-site work
- Factory tools - jigs, cranes, conveyors, etc. - can make production faster and more precise
- Factory tools - shake tables, hydraulic testers, etc. - can offer added quality assurance
- Consistent indoor environments of factories eliminate most impacts of weather on production
- Cranes and reusable factory supports can allow shapes and sequences without expensive on-site falsework
- Higher-precision factory tools can aid more controlled movement of building heat and air, for lower energy consumption and healthier buildings
- Factory production can facilitate more optimal materials usage, recycling, noise capture, dust capture, etc.
- Machine-mediated parts movement, and freedom from wind and rain can improve construction safety
- Homogeneous manufacturing allows high standardization and quality control, ensuring quality requirements subject to performance and resistance tests, which also facilitate high scalability of construction projects. [5]
- The specific production processes in industrial assembly lines allow high sustainability, which enables savings of up to 20% of the total final cost, as well as considerable savings in indirect costs. [6]

Disadvantages

[edit]

- Transportation costs may be higher for voluminous prefabricated sections (especially sections so big that they constitute oversize loads requiring special signage, escort vehicles, and temporary road closures) than for their constituent materials, which can often be packed more densely and are more likely to fit onto standard-sized vehicles.
- Large prefabricated sections may require heavy-duty cranes and precision measurement and handling to place in position.

Off-site fabrication

[edit]

Off-site fabrication is a process that incorporates prefabrication and pre-assembly. The process involves the design and manufacture of units or modules, usually remote from the work site, and the installation at the site to form the permanent works at the site. In its fullest sense, off-site fabrication requires a project strategy that will change the orientation of the project process from construction to manufacture to installation. Examples of off-site fabrication are wall panels for homes, wooden truss bridge spans, airport control stations.

There are four main categories of off-site fabrication, which is often also referred to as off-site construction. These can be described as component (or sub-assembly) systems,

panelised systems, volumetric systems, and modular systems. Below these categories different branches, or technologies are being developed. There are a vast number of different systems on the market which fall into these categories and with recent advances in digital design such as building information modeling (BIM), the task of integrating these different systems into a construction project is becoming increasingly a "digital" management proposition.

The prefabricated construction market is booming. It is growing at an accelerated pace both in more established markets such as North America and Europe and in emerging economies such as the Asia-Pacific region (mainly China and India). Considerable growth is expected in the coming years, with the prefabricated modular construction market expected to grow at a CAGR (compound annual growth rate) of 8% between 2022 and 2030. It is expected to reach USD 271 billion by 2030. [7]

See also

[edit]

 not found or type unknown

Wikimedia Commons has media related to ***Prefabrication***.

- Prefabricated home
- Prefabricated buildings
- Concrete perpend
- Panelák
- Tower block
- St Crispin's School — an example of a prefabricated school building
- Nonsuch House, first prefabricated building
- Agile construction
- Intermediate good

References

[edit]

- [^] (2022) Modularity clustering of economic development and ESG attributes in prefabricated building research. *Frontiers in Environmental Science*, 10. Retrieved from <https://www.frontiersin.org/articles/10.3389/fenvs.2022.977887>
- [^] *Sargeant, Tony Anthony J. (11 November 2016) [2016-09-10]. "'Prefabs' in South London – built as emergency housing just after WW2 and meant to last for just 10 years". *Tonyjsargeant.wordpress.com*. Archived from the original on 14 October 2016. Retrieved 19 July 2018.*
- [^] *Goh, Edward; Loosemore, Martin (4 May 2017). "The impacts of industrialization on construction subcontractors: a resource based view". *Construction Management and Economics*. **35** (5): 288–304. doi:10.1080/01446193.2016.1253856. ISSN 0144-6193.*
- [^] Details about the modular construction market. *Hydrodiseno.com*. 2022-08-17. Retrieved 2023-01-05

Streetwalker Tours

0 (0)

Photo

Image not found or type unknown

The Tulsa Arts District

4.7 (22)

Photo

Image not found or type unknown

Guthrie Green

4.7 (3055)

Photo

Tulsa Zoo

4.5 (10481)

Photo

Image not found or type unknown

Tulsa Air and Space Museum & Planetarium

4.3 (419)

Photo

Image not found or type unknown

Philbrook Museum of Art

4.8 (3790)

Driving Directions in Tulsa County

Driving Directions From Subway to Durham Supply Inc

Driving Directions From East Central High School to Durham Supply Inc

Driving Directions From Camp Bow Wow to Durham Supply Inc

Driving Directions From Oakwood Homes to Durham Supply Inc

Driving Directions From Nights Stay Hotel to Durham Supply Inc

Furnace store

Heating contractor

HVAC contractor

Mobile Home Furnace Installation

Mobile Home Air Conditioning Installation Services

Driving Directions From Gathering Place to Durham Supply Inc

Driving Directions From The Blue Dome to Durham Supply Inc

Driving Directions From Philbrook Museum of Art to Durham Supply Inc

Driving Directions From Bob Dylan Center to Durham Supply Inc

Driving Directions From The Cave House to Durham Supply Inc

Driving Directions From Philbrook Museum of Art to Durham Supply Inc

[Mobile home supply store](#)

[Air conditioning repair service](#)

[Air conditioning store](#)

[Air conditioning system supplier](#)

[Furnace repair service](#)

Reviews for Durham Supply Inc

Durham Supply Inc

Image not found or type unknown

Dennis Champion

(5)

Durham supply and Royal supply seems to find the most helpful and friendly people to work in their stores, we are based out of Kansas City out here for a few remodels and these guys treated us like we've gone there for years.

Durham Supply Inc

Image not found or type unknown

Ethel Schiller

(5)

This place is really neat, if they don't have it they can order it from another of their stores and have it there overnight in most cases. Even hard to find items for a trailer! I definitely recommend this place to everyone! O and the prices is awesome too!

Durham Supply Inc

Image not found or type unknown

B Mann

(5)

I was in need of some items for a double wide that I am remodeling and this place is the only place in town that had what I needed (I didn't even try the other rude place)while I was there I learned the other place that was in Tulsa that also sold mobile home supplies went out of business (no wonder the last time I was in there they were VERY RUDE and high priced) I like the way Dunham does business they answered all my questions and got me the supplies I needed, very friendly, I will be back to purchase the rest of my items when the time comes.

Durham Supply Inc

Image not found or type unknown

Gerald Clifford Brewster

(5)

We will see, the storm door I bought says on the tag it's 36x80, but it's 34x80. If they return it.....they had no problems returning it. And it was no fault of there's, you measure a mobile home door different than a standard door!

Durham Supply Inc

Image not found or type unknown

Ty Spears

(5)

Bought a door/storm door combo. Turns out it was the wrong size. They swapped it out, quick and easy no problems. Very helpful in explaining the size differences from standard door sizes.

Navigating Trane Models for Mobile Home Heating [View GBP](#)

Frequently Asked Questions

What are the key considerations when choosing a Trane model for heating a mobile home?

Key considerations include the size of the mobile home, energy efficiency ratings (such as SEER and HSPF), compatibility with existing ductwork or systems, and climate zone requirements. Its important to select a model that meets the specific heating needs without oversizing, which can lead to inefficiency.

Are there specific Trane models recommended for mobile homes?

While Trane does not have models exclusively labeled for mobile homes, their compact and efficient heat pumps and furnaces like the XR14 or S9X1 series are often suitable. These models offer reliable performance with good energy efficiency, making them ideal for smaller spaces like mobile homes.

How do I ensure proper installation of a Trane HVAC system in my mobile home?

Proper installation requires hiring a qualified HVAC technician who is experienced with mobile home systems. They should assess your home's specifications, ensure correct sizing of the unit, verify ductwork compatibility, and make necessary adjustments to optimize airflow and efficiency.

What maintenance is required for keeping a Trane heating system efficient in a mobile home?

Regular maintenance includes changing air filters every 1-3 months, scheduling annual professional inspections to check components like coils and electrical connections, ensuring vents are unobstructed, and cleaning any debris from around external units. This helps maintain optimal performance and extend system longevity.

Royal Supply Inc

Phone : +16362969959

City : Oklahoma City

State : OK

Zip : 73149

Address : Unknown Address

Google Business Profile

Company Website : <https://royal-durhamsupply.com/locations/oklahoma-city-oklahoma/>

Sitemap

Privacy Policy

About Us

Follow us